

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151679, Building Permit - Commercial
Address: 897 NE BLUESTEM DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, October 20, 2015

Partial Correction

1	THE FOLLOWING AREAS ARE APPROVED	-UNDERGROUND ELECTRICAL SERVICE FROM LEGACY CENTER TO THREE BUILDINGS -UE TO LIGHT POLES-OK AS PROGRESSED -5 LP PIERS-OK AS PROGRESSED -3 LP NORTH SIDE-INSTALL 4-#6 REBARS, NOT #4
---	----------------------------------	--

Comments: