

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141075, Building Permit - Commercial
Address: 3321 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Wednesday, October 21, 2015

Corrective Action Required

1	Misc 1	BSMT COMPLETE
---	--------	---------------

Corrective Action Required

2	FIRST FLOOR	PVC 4" DRAIN COLLARS
---	-------------	-------------------------

Corrective Action Required

3	SECOND FLOOR	FULL LIST SEE NIC- PROTECTIONI PLATES ELECTRICAL PANELS INCOMPLETE CAULK PVC 4" ROOF DRAINS FIRESTOP BETWEEN UNITS
---	--------------	--

Sprinkler - Hydrostatic Test	Michael Weissenbach	Passed	Wednesday, October 21, 2015
-------------------------------------	---------------------	--------	-----------------------------

Comments: