

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Thursday, October 22, 2015

Rated Assembly Inspection	John Borns	Partial	Thursday, October 22, 2015
--------------------------------------	------------	---------	----------------------------

Partial Correction
1 Misc 1

1ST FLOOR:
OK TO TAPE, MUD & FIRE-STOP:
RATED CEILINGS AND WALLS AT ALL UNITS ELEVATOR MACHINE
ROOM; E108; CORRIDOR CEILING AND WALLS; 119 EXCEPT
SOUTH WALL; 120 EXCEPT NORTH WALL;

Partial Correction
2 Misc 1

2ND FLOOR: OK TO TAPE, MUD & FIRESTOP: CORRIDOR CEILING
AND WALLS; RATED CEILINGS AND WALLS AT: ALL UNITS; 208;
219; 220;

Partial Correction
3 Misc 1

3RD FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE
X GWB AT: CORRIDOR CEILING; ELECT & DATA RMS WALLS.
WALLS AND CEILINGS AT UNITS 302*; 311; 312*; 313; 314; 315;
317; 318; 321; 323; 324; 327; 332; 333; CORRIDOR WALLS; 319;
320;

*EXCEPT ROOF DRAINS & STAIRWELL WALLS
STAIRWELL WALLS NOT READY FOR INSPECTION

Partial Correction
4 Misc 1

4TH FLOOR: OK TO TAPE, MUD & FIRE-STOP ONE LAYER 5/8" TYPE
X GWB AT: UNITS 412; 413*; 414*; 423; 424; 427*; CORRIDOR
WALLS ONLY ; E428; E429; 411; 419; 420; CORRIDOR CEILING

Partial Correction

5	Misc 1	OK TO TAPE, MUD AND FIRE-SEAL CEILINGS AND WALLS AT ELEVATOR LOBBIES AT: 4TH FLR; 3RD FLR; 2ND FLR;
Corrective Action Required		
6	Misc 1	PROTECTION OF PENETRATIONS TO BE SPECIFIED BY A/E;
Partial Correction		
7	Misc 1	RATED WALLS AT STAIRWELL SHAFTS: OK TO COVER WHEN READY 1" SHAFT LINER IN PLACE AT EAST & WEST STAIR TOWERS FROM 1ST FLR TO 4TH FLR ELEVATION.

Comments: ELECTRICAL SERVICE IS RELEASED FOR ACTIVATION CONTINGENT ON:

- 1) WET PIPING ABOVE THE MAIN GEAR MUST BE RELOCATED OR ISOLATED FROM EQUIPMENT BELOW.**
- 2) DOOR OPENINGS AT E126, E226, E326 AND E426 IMPINGE ON 30" W x 36" WIDE x HEIGHT OF EQUIPMENT DEDICATED WORKING SPACE IN FRONT OF ELECTRICAL EQUIPMENT INSIDE. HINGED EQUIPMENT DOORS MUST OPEN FOR WORK AND SERVICE.**