

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141077, Building Permit - Commercial  
Address: 3341 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Thursday, October 22, 2015

### Corrective Action Required

1	Misc 1	1ST LAYER INSIDE ELEVATOR ELEVATOR CEILING-1ST,2,3, 4 LAYERS APPROVED SOUTH TOWER 1ST LAYER NORTH TOWER 1-2 1ST LAYER 2nd layer partial - CORRIDOR CEILING 2ND LAYER 1,2,3 TUB WALLS- 2HR TUB WALLS 1ST,2ND LAYERS units 1st layer 1st floor unit side 1st layer 2nd,3,4th ceiling only 1ST LAYERS STAIR TOWER CEILING AND DROP 1st,2ND LAYER ELEVATOR EQUIPMENT ROOM
Partial Correction		
2	FIRST FLOOR	1st floor garage need to enclose north garage i beam 2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction		
3	SECOND FLOOR	2ND LAYER 2 HOUR CONDITIONS APPROVED
Partial Correction		
4	THIRD FLOOR	1ST LAYER WALLS AND CEILING APPROVED 2hr walls- unit bathrooms 6304,6305,6306 nail patterN 2ND LAYER WALLS @ 2 HR CONDITIONS - 3RD FLOOR; 1ST LAYER CORRIDORS STAIR TOWERS AT SIDE ENTRY;
Partial Correction		
5	FOURTH FLOOR	1ST LAYER WALLS AND CEILING APPROVED 2ND LAYER 2ND LAYERS 2HR WALLS

**Comments:**