

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20152357, Building Permit - Commercial
Address: 471 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Passed	Friday, October 23, 2015

Comments: NO ISSUES FOUND ON INSTALLATION OF UNDERGROUND CONDUIT AND GROUNDING SYSTEM AT GENERATOR PAD LOCATION. OK TO COVER WHEN READY.