

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141075, Building Permit - Commercial
Address: 3321 SW KESSLER DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Friday, October 23, 2015

Corrective Action Required

1	Misc 1	BSMT COMPLETE
---	--------	---------------

Corrective Action Required

2	FIRST FLOOR	PVC 4" DRAIN COLLARS
---	-------------	-------------------------

Corrective Action Required

3	SECOND FLOOR	FULL LIST SEE NIC- PROTECTIONI PLATES ELECTRICAL PANELS INCOMPLETE CAULK PVC 4" ROOF DRAINS FIRESTOP BETWEEN UNITS
---	--------------	--

Corrective Action Required

4	THIRD FLOOR	elect, google , puddy pads, carl bath vents 4" drainetc bath fans truss failed
---	-------------	---

Corrective Action Required

5	FOURTH FLOOR	walked not ready
---	--------------	------------------

Rated Assembly Inspection	Mark Harding	Partial	Friday, October 23, 2015
----------------------------------	--------------	---------	--------------------------

Corrective Action Required

1	THE FOLLOWING AREAS ARE APPROVED	2ND LAYER ELEVATOR CEILING CALLED IN BY NICK @ 913-653-4490 SALLY SARVADI 09/09/2015 2:21 PM 1ST LAYER ELEVATOR, WALL CEILING- 2ND LAYER WALLS, 2ND LAYER CEILING COVERED BY 3RD LAYER9/9,
---	----------------------------------	---

3RD COVERED BY 4TH 9/10
caulking of tub traps
DRYER BOXES B-4-OK
corridor ceiling b,1,2,3

Comments: