

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150873, Building Permit - Commercial
Address: 200 NE MISSOURI RD, Unit:306, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Monday, October 26, 2015

Corrective Action Required
2 Misc 1

NEC 210-8(B)(5); IRC 3902: GFCI PROTECTION OF ELECTRICAL RECEPTACLES: ELECTRICAL RECEPTACLES WITHIN 6' OF EDGE OF SINK MUST BE GFCI-PROTECTED. GFCI DEVICES THAT ARE INSTALLED ARE NOT TRIPPING.

**NONE OF THE INSTALLED GFCI TRIPP. THE RECEPTACLE WITHIN 6 FT OF THE LAB WASH SINK IS NOT GFCI

Corrective Action Required
4 Misc 1

SUITE ENTRY DOORS MUST BE ADDRESSED

**ALSO ADJUST DOORS CLOSING FORCE TO 5 LBS OR LESS

Corrective Action Required
6 Misc 1

-OBTAIN FIRE APPROVAL

Comments: