

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151488, Building Permit - Residential
Address: 3106 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Monday, October 26, 2015
Gas Piping Inspection - Residential	Mike Copeland	Passed	Monday, October 26, 2015
Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, October 26, 2015
All Rough Inspection - Residential	Mike Copeland	Failed	Monday, October 26, 2015

Corrective Action Required

1 Misc 1

- SECURITY BLOCK BACK DOOR
- NAIL GARAGE PORTAL SILL 3"
- SEAL PENETRATIONS IN FIREBLOCKING AND TOP PLATE OF GARAGE
- SOLID BLOCK OVER FRONT DOOR
- FIREBLOCK MECHANICAL CHASE TO ATTIC

OKAY TO INSULATE

Corrective Action Required

2

Comments:

