



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20151723	Date:	October 27, 2015
Project Title:	JIMMY JOHN'S	Applicant:	
Location:	3680 NE AKIN DR, Unit:142, LEES SUMMIT, MO 64064	AEGIS FIRE PROTECTION LLC	11936 W 119TH ST OVERLAND PARK, KS 66213
Type of Work:		Primary:	(913) 825-0343
Occupancy Group:	A-2		
Description:	TENANT FINISH FOR NEW SANDWICH RESTAURANT		
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
FIRE SPRINKLER SYSTEM SHALL HAVE A CURRENT SERVICE TAG ON THE RISER. VERIFIED AT INSPECTION

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.