

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141074, Building Permit - Commercial  
Address: 3311 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Mark Harding	Failed	Tuesday, October 27, 2015

### Corrective Action Required

1	Misc 1	BASEMENT-OK 1ST FLOOR-UNITS OK 2ND FLOOR-01,02,04,05,06 BLOW OFF 3RD FLOOR NOT INSPECTED 4TH FLOOR- PLUMBING BLOW OFF PIPING HVAC CUT IN CEILING FOR HOOD 4400,12,13,11,08,09,07,06, 05 CUT CABINET OUTLET FOR HOOD. INSTALL 3M PILLOWS IN CONDUIT THROUGH FLOORS INSPECT ROOF NORTH WALL HEATER 1ST FLOOR INCOMPLETE STORAGE 8 PVC, S12 PVC IT ROOM , JANITOR CLOSET, OPEN BOX SOUTH EXTERIOR OF BUILDING.
---	--------	--

### Corrective Action Required

2			
<b>Alarm Test</b>	Joe Dir	Passed	Tuesday, October 27, 2015
<b>Sprinkler - Flow Test</b>	Joe Dir	Passed	Tuesday, October 27, 2015
<b>Occupancy Inspection - Fire</b>	Joe Dir	Temporary C of O	Tuesday, October 27, 2015

**Occupancy Inspection - Hector Soto  
Planning**

Failed

Tuesday, October 27, 2015

Corrective Action Required

1

Installation of balcony railing on the east side of the building is not complete.

**Comments:**