

Temporary Certificate of Occupancy

Permit #: PRCOM20143335
Address: 200 NE MISSOURI RD, Unit:100, LEES SUMMIT, MO 64086
Inspected On: Wednesday, October 28, 2015
Inspected By: John Borns
Expiration Date: 11/26/2015 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|------------------|--------------------------------|
| Occupancy Inspection - Codes Commercial | John Borns | Temporary C of O | Wednesday, October 28, 2015 |

Corrective Action Required:

1 Misc 1 ELECTRICAL RECEPTALCES IN CABINETS ABOVE SINKS AT THE TWO SOUTH EXAM ROOMS NOT GFCI-PROTECTED.

Corrective Action Required:

3 Misc 1 "NO SMOKING" SIGNS REQUIRED AT PUBLIC ENTRANCE DOORS.

Corrective Action Required:

4 Misc 1 LABELED DOORS A143b, A151 AND A155 SUBJECT TO APPROVAL WHEN INSTALLED PERMANENT.

Corrective Action Required:

6 Misc 1 RESOLVE ANY FIRE DEPARTMENT ISSUES.