

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20152487, Building Permit - Commercial
Address: 208 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Passed	Wednesday, October 28, 2015

Gas Piping Inspection - Commercial	John Borns	Failed	Wednesday, October 28, 2015
---	------------	--------	-----------------------------

Corrective Action Required

1	Misc 1	IFGC 404.8: METALLIC PIPING EXPOSED TO WEATHER MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS. SEE GAS PIPING AT METER AND ROOFTOP.
---	--------	--

Corrective Action Required

2	Misc 1	ADDRESS LABELING OF GAS SERVICE ENTRY PIPE: HANG PERMANENT TAG FROM LOAD SIDE ENTRY PIPE. FELT TIP MARKER NOT APPROVABLE.
---	--------	---

Comments: GAS SERVICE RELEASED CONTINGENT ON RESOLUTION OF ABOVE TWO ISSUES. CALL FOR RE-INSPECTION WHEN READY.