



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No: PRCOM20152145 Date: October 29, 2015
Project Title: UPS WHITE BOX AT RAINTREE VILLAGE CENTER Applicant:
Location: 833 SW LEMANS LN, LEES SUMMIT, MO 64082 ALLIANCE FIRE PROTECTION LLC
130 W 9TH AVE STE 101
KANSAS CITY, MO 64116
Type of Work: Primary: (913) 888-0647
Occupancy Group: N/A
Description: ALTERATION TO CONVERT INTO
WHITE BOX - OCCUPANCY TO BE
GRANTED AT FUTURE TENANT
FINISH
Construction Type: Type IIB (Unprotected)
Map Page:

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.
sprinkler system shall be current with the annual service / maintenance. current service tag on riser. verified at inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.