

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, October 29, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY CEILINGS AT MAIN CORRIDORS AT:
LEVEL 2 EXCEPT ONE PENETRATION AT WEST END;

**AT LEVEL 3 FIRE-STOP ALL OPENINGS AND PENETRATIONS AT
WALLS AND CEILINGS;**

Rated Assembly Inspection	John Borns	Partial	Thursday, October 29, 2015
----------------------------------	------------	---------	----------------------------

Partial Correction
7 Misc 1

RATED WALLS AT STAIRWELL SHAFTS:
EAST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER
FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT;

WEST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER
FULL HEIGHT; **1ST LAYER 1/2" GWB FULL HEIGHT, WITH JOINT
GAPS BEING FILLED AS PART OF PROCESS;**

Comments: