

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20151583, Building Permit - Residential  
Address: 262 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Thursday, October 29, 2015

### Corrective Action Required

1 Misc 1

- FIREBLOCK DOUBLE WALL GARAGE.
- NAIL GARAGE PORTAL SILL
- STRAP AND NAIL READ WALL PER DETAIL AT DINETTE.
- RE-INSTALL REAR SECURITY BLOCK
- NAIL EXTERIOR CORNER STUDS 12" O.C.
- INSTALL TWO ANCHOR BOLTS PER PLATE SECTION IN BASEMENT.

Do not insulate

### Corrective Action Required

2

### Comments: