

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, October 30, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY UNDER-SLAB: 4" PVC SANITARY
DRAIN & 2" VENT PIPING AT WASH BAYS; **2"W FROM DBL SINK
@ [116] WEST TO TIE-IN TO EXISTING TO NW**

NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING
SYSTEM.

Comments: