

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Electrical Inspection - Commercial	John Borns	Partial	Friday, October 30, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY UNDER-SLAB 3/4" PVC CONDUIT AT SALES TOWER [115]	
Underslab Plumbing Inspection - Commercial	John Borns	Partial	Friday, October 30, 2015
Partial Correction 1 Misc 1		OK TO COVER WHEN READY UNDER-SLAB: 4" PVC SANITARY DRAIN & 2" VENT PIPING AT WASH BAYS; 2"W FROM DBL SINK @ [116] WEST TO TIE-IN TO EXISTING TO NW NOTE IPC 312 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM.	

Comments: