

220 SE GREEN ST.
LEE'S SUMMIT, MO 64063

PHONE: 816-969-1200
FAX: 816-969-1201

CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

ADDRESS: 1174 NE Douglas St PERMIT NUMBER: PRC 1120150837
LOT NUMBER: _____ SUBDIVISION: Douglas Station INSPECTION: Re-Occupancy
CONTRACTOR: Zipcar PHONE NUMBER: _____
PROJECT: Storm Damage Restoration

1. FOOTING	S <u> </u> U <u> </u>	7. GAS PIPING	S <u> </u> U <u> </u>	12. POOL BONDING	S <u> </u> U <u> </u>
2. SEWER/WATER	S <u> </u> U <u> </u>	8. GAS SERVICE	S <u> </u> U <u> </u>	13. SPRINKLER SYSTEM	S <u> </u> U <u> </u>
3. FRAMING	S <u> </u> U <u> </u>	9. GROUND PLUMBING	S <u> </u> U <u> </u>	14. OCCUPANCY	S <u> </u> U <u> </u>
4. MECHANICAL	S <u> </u> U <u> </u>	10. TOP ROUGH PLUMBING	S <u> </u> U <u> </u>	15. FINAL APPROVAL	S <u> </u> U <u> </u>
5. ELECTRICAL	S <u> </u> U <u> </u>	11. DECK PIERS	S <u> </u> U <u> </u>	16. EROSION CONTROL	S <u> </u> U <u> </u>
6. ELECTRIC SERVICE	S <u> </u> U <u> </u>				

Certificate of Occupancy issued 6/25/2015
is hereby reinstated contingent on:

- 1) Correct three electrical receptacles to
make flush with combustible surface
and make all solid to box.
- 2) Affix "No Smoking" sign to public entrances.

INSPECTOR: John Borns DATE: 10/16/15 TIME: _____ MILEAGE: _____

DO NOT COVER OVER WORK UNTIL APPROVED - CALL FOR REINSPECTION OF UNSATISFACTORY WORK

LEGEND:

***S = SATISFACTORY**

***U = UNSATISFACTORY (reinspection required)**