

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152091, Building Permit - Commercial  
Address: 13 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Partial	Friday, October 30, 2015

Corrective Action Required

1	Misc 1	SURFACE-MOUNTED ELECTRICAL JUNCTION BOX AT MEZZANINE NEEDS THREE BLUNDER PLUGS.
---	--------	---

Corrective Action Required

2	Misc 1	POST SPACE ADDRESS NUMBER AT ENTRANCE.
---	--------	--

Corrective Action Required

3	Misc 1	DISPLAY "NO SMOKING" SIGN AT PUBLIC ENTRANCE.
---	--------	---

Corrective Action Required

4	Misc 1	SINK TRAP MUST DISPLAY LISTING MARKING.
---	--------	---

Corrective Action Required

5	Misc 1	RESOLVE ANY FIRE DEPARTMENT ISSUES.
---	--------	-------------------------------------

Corrective Action Required

6	Misc 7	<b>OCCUPANCY STATUS: OK FOR TEMPORARY OCCUPANCY THROUGH 11/5/2015 CONTINGENT ON FIRE DEPARTMENT APROVAL.</b>
---	--------	--

Comments: