

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Friday, October 30, 2015

Partial Correction
1 Misc 1

RATED WALLS AT STAIRWELL SHAFTS:

EAST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; **2ND LAYER 1/2" GWB FULL HEIGHT**

WEST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; **EAST WALL ONLY 2ND LAYER 1/2" GWB FULL HEIGHT**

Comments: