



11656 W. 75th Street Shawnee, KS 66214

P: (913) 631-2222 D: (800) 780-8608 Solutions for all your engineering and design needs

October 30, 2015

Wyss Construction, LLC PO Box 6620 27400 Mason School Rd Lee's Summit, MO 64064

## Re: 3928 NE Independence Avenue

Our firm was asked to address a framing inspection item for the house being framed at 3928 NE Independence Avenue for Wyss Construction.

## Notched Header at Master Bath

The framer has notched the bottom of the header to allow passage of a plumbing vent. To allow the header to properly transfer load at this location and additional double 2x10 header will need to be placed above the notched header to allow proper transfer of loads at this location.

This report has been prepared for the exclusive use of our client for specific application to the project discussed and has been prepared in accordance with generally accepted engineering practices. No warranties, either express or implied, are intended or made.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please contact us.

Very truly yours, HD ENGINEERING & DESIGN, INC.

John Hulse, Princi RECEIVED OCT 30 2015 Chris Saathoff, RE 2015-Planning & Codes Admin SIONAL www.hdengineers.com