

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150890, Building Permit - Residential
Address: 3928 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, November 02, 2015

Corrective Action Required

1	Misc 1	FRAMING: -HAVE PLAN ON SITE FOR REINSPECTION -BLOCK THE REAR DOOR STUDS AND FILL IN GAP AT STRIKE PLATE SIDE PER LS SECURITY CODE **SHIM THE EXCESSIVE GAP -FIREBLOCK KITCHEN WALL AT REFRIGERATOR FROM ATTIC **NOT DONE -PROVIDE R-15 THERMAL ENVELOP AT GARAGE RETURN AIR **NEED THE R-15 THERMAL ENVELOPE FOR THE ENTIRE HEIGHT OF THE WALL **OK TO INSULATE
---	--------	---

Comments: