

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, November 02, 2015
Partial Correction 1      Misc 1		OK TO COVER WHEN READY ACT CEILINGS AT MAIN CORRIDORS AT: <b>AT LEVEL 3 OK TO PLACE TILE EAST OF LOW-VOLTAGE ROOM + 3" BORDERS OK; FIRE-STOP ALL OPENINGS AND PENETRATIONS AT WALLS AND CEILINGS WEST OF THERE</b>  <b>AT LEVEL 2 BORDERS &lt;=3" OK;</b>	
<b>Rated Assembly Inspection</b>	John Borns	Partial	Monday, November 02, 2015
Partial Correction 1      Misc 1		RATED WALLS AT STAIRWELL SHAFTS: <b>EAST STAIR SHAFT:</b> OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; 2ND LAYER 1/2" GWB FULL HEIGHT; <b>OK TO INSTALL FINISH LAYER 5/8" TYPE X GWB;</b>  WEST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; EAST WALL ONLY 2ND LAYER 1/2" GWB FULL HEIGHT	

Comments: