

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20151616, Building Permit - Commercial
Address: 2600 NE INDEPENDENCE AVE, Unit:A, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Friday, November 06, 2015

Corrective Action Required

1	Misc 1	-COMPLETE RESTROOM **THE ELECTRICAL BOX CANNOT BE RECESSED MORE THAN 1/4" BEHIND THE NON-COMBUSTIBLE WALL FINISH **THE BATH SIGN MUST BE ON THE WALL ON THE LATCH SIDE OF THE DOOR
---	--------	--

Comments: