

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Borns	<b>Not Ready</b>	Monday, November 09, 2015

Partial Correction  
1 Misc 1

RATED WALLS AT STAIRWELL SHAFTS:  
EAST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; 2ND LAYER 1/2" GWB FULL HEIGHT; OK TO INSTALL FINISH LAYER 5/8" TYPE X GWB;

WEST STAIR SHAFT: OK TO COVER WHEN READY 1" SHAFT LINER FULL HEIGHT; 1ST LAYER 1/2" GWB FULL HEIGHT; EAST WALL ONLY 2ND LAYER 1/2" GWB FULL HEIGHT; OK TO INSTALL FINISH LAYER 5/8" TYPE X GWB ALL WALLS FULL HEIGHT

<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, November 09, 2015
---------------------------------	------------	---------	---------------------------

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY ACT CEILINGS AT **MAIN CORRIDORS AT: LEVEL 3; LEVEL 2;**

Comments: