

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20152121, Building Permit - Commercial
Address: 1601 SW MANOR LAKE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mark Harding	Partial	Tuesday, November 10, 2015

Corrective Action Required
1 Misc 1

FRAMING INSPECTION
ELECTRICAL ROUGH INSPECTION

OK TO ROCK -EXCEPT AT UFFER GROUND AND AT PANEL FOR
INSPECTION OF SE CABLE.

PANEL NOT INSPECTED

Comments: