

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20141214, Building Permit - Commercial
Address: 304 SW PERSELS RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mark Harding	Failed	Wednesday, November 11, 2015

Corrective Action Required

1	Misc 1	PARTIAL FINAL INSPECTION- PROVIDE APPROVAL FROM ALL DEPARTMENTS PRIOR TO OCCUPYING. CODES PLANNING WATER PUBLIC WORKS FIRE DEPT.
---	--------	---

Corrective Action Required

2	Misc 1	ok to stock and train on AV systems. NOT TO BE OPEN FOR SERVICES OR TO THE PUBLIC.
---	--------	---

Corrective Action Required

3	Misc 1	-turn down water heater blow off drain in north mop sink -gfcis at east and west of main front doors are not hot. (south entry) -roof drains south front entry incomplete -place electrical plaque on wall at electrical room. -complete labels of all electrical panels -provide state elevator inspection -install handrail south main stairs to 2nd floor -bath fan not working 2005A -complete vanities at 2nd floor children's bathroom. -cap drain in room 1105 for ice machine -provide backflow on ice machine in coffee area
---	--------	---

Pending TCO or C of O approval from other departments.
Planning
Fire
Water
Public Works
Codes

Comments: