

FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

November 13, 2015

CITY OF LEES SUMMIT PO BOX 1600 LEES SUMMIT, MO 64063--7600

Permit No: PRCOM20152658

Project Title: EAA HANGAR PROPANE TANK AND HEATERS
Project Address: 2750 NE DOUGLAS ST, LEES SUMMIT, MO 64064

Parcel Number: 52300010400000000

Location: SEC 19 TWP 48 RNG 31 BEG NE COR OF SEC TH W 960' TH S 1600' TH W 360' TH S

1043' TH E 1320' TH N 2640' TO POB & N 1/2 VAC LEINWEBER RD LY S & ADJ

Type of Work: ALTERATION COMMERCIAL

Occupancy Group:

Description: NEW PROPANE HEATERS AND EXTERIOR 500 GALLON TANK

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200 Fire Department (816) 969-1300

Building Plan Review Reviewed By: Joe Frogge Approved

Fire Plan Review Reviewed By: Joe Dir Approved with Conditions

1. 6104.3 Container location.

LP-gas containers shall be located with respect to buildings, public ways and lot lines of adjoining property that can be built upon, in accordance with Table 6104.3. IFC 2012 edition

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.