

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151240, Building Permit - Residential
Address: 428 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	Mike Copeland	Passed	Tuesday, November 17, 2015

Gas Service Inspection - Residential	Mike Copeland	Failed	Tuesday, November 17, 2015
---	---------------	--------	----------------------------

Corrective Action Required
1 Misc 1

NO TEST PRESSURE

All Rough Inspection - Residential	Mike Copeland	Failed	Tuesday, November 17, 2015
---	---------------	--------	----------------------------

Corrective Action Required
1 Misc 1

-INSTALL SECURITY BLOCK REAR DOOR.
-NAIL SIDING PER CS-PF DETAIL REAR GREAT ROOM WALL.
-INSTALL STUD OR HEADER SUPPORT FOR GIRDER TRUSS OVER BED 2.
-FIRESTOP TUB TRAPS AND PENETRATIONS IN FIREBLOCK.
-BASEMENT, SOLID BLOCK CANTILEVER INTO GARAGE.
-INSTALL HANGER FOR LVL OVER FOYER.
-NAIL SILLS EVERY 12" INTO RIMS.

Do not insulate

Corrective Action Required
2

Comments: