

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20141075, Building Permit - Commercial  
Address: 3321 SW KESSLER DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mark Harding	Partial	Tuesday, November 17, 2015

Corrective Action Required  
1 FOURTH FLOOR

FIRST LAYER LID APPROVED

1st layer south tower ok walls and ceiling

1st layer north tower ceiling ok  
walls not screwed off

2nd layers corridor and ceiling not complete

**Comments:**