

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150658, Building Permit - Commercial
Address: 2751 NE DOUGLAS ST, Unit:R, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Thursday, November 19, 2015

Corrective Action Required

1	Misc 1	-WATER DEPT APPROVAL REQUIRED **INSTALL BACKFLOW DEVICE FOR WATER SERVICE -STAIR GUARDRAIL (MIN 42") REQUIRED
---	--------	---

Comments: