

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20150014, Building Permit - Commercial  
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Monday, November 23, 2015

Partial Correction  
1          Misc 1

OK TO COVER WHEN READY ACT CEILINGS AT MAIN CORRIDORS  
AT: LEVEL 3; LEVEL 2; LEVEL 1; LEVEL 4; **E219;**

**E119: NO GRID; NOT READY FOR INSPECTION**  
**E319: 5"x9" HOLE IN GWB LID; COMPLETE FRIE-SEALING OF ALL  
OPENINGS/PENETRATIONS**  
**E419: COMPLETE WRAPPING/SEALING OF DUCT INSULATION;  
FIRE-STOP PENETRATION BY 6" PVC PIPE NEAR E WALL; SOME  
ELECT BOXES NOT CLOSED; COMPLETE FIRE-STOPPING OF ALL  
OPENINGS/PENETRATIONS**

Comments: