



LEE'S SUMMIT
MISSOURI

CODE MODIFICATION REQUEST
(INSPECTIONS)

BUILDING/STRUCTURE NAME: Abundant Life Baptist Church

PREMISE ADDRESS: 304 Southwest Persels Road

PERMIT NUMBER (If applicable): 20141214

OWNER'S NAME: Abundant Life Baptist Church

TO: Director of Planning & Codes Administration

In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)

We have a small 3 compartment sink in a cabinet at the coffee bar in the entry of the church. The waste is hard piped, not to an indirect drain. The food preparation consists of unwrapping muffins and bagels and rewarming them in a microwave. No cooking is anticipated and the cleanup of any utensils will be at the adjacent dishwasher. We believe we are in a bit of a gray area and would like to have a code modification to allow the hard pipe drain. If necessary, we can use signage to instruct the servers to use the dishwasher for washing silver and any cups and saucers.

SUBMITTED BY:

NAME: Dale K. Dickson - Shafer Kline & Warren ☐ OWNER ☒ OWNER'S AGENT

ADDRESS: 1700 Swift Tel.# 816-502-3950

CITY, STATE, ZIP: North Kansas City Mo 64116 SIGNATURE: Dale K. Dickson

MIKE COPELAND - INSPECTION SERVICES DIVISION MANAGER: ☒ APPROVAL ☐ DENIAL

Tracy Deister - Asst Dir. Codes Admin
SIGNATURE: [Signature] DATE: 11-19-15

ROBERT MCKAY - DIRECTOR OF PLANNING & CODES ADMIN: ☐ APPROVED ☐ DENIED

SIGNATURE: This is Bob's Church so he will not be signing. RTO

COMMENTS: Install sign stating "No Food Prep or Washing Dishes"

A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE