

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151240, Building Permit - Residential
Address: 428 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Tuesday, November 24, 2015

Corrective Action Required

1 Misc 1

*****NO ACCESS TO HOUSE. LOCKBOX CODE IS NOT PROVIDED.
WASTED TRIP FEE ASSESSED

- INSTALL SECURITY BLOCK REAR DOOR.
- NAIL SIDING PER CS-PF DETAIL REAR GREAT ROOM WALL.
- INSTALL STUD OR HEADER SUPPORT FOR GIRDER TRUSS OVER BED 2.
- FIRESTOP TUB TRAPS AND PENETRATIONS IN FIREBLOCK.
- BASEMENT, SOLID BLOCK CANTILEVER INTO GARAGE.
- INSTALL HANGER FOR LVL OVER FOYER.
- NAIL SILLS EVERY 12" INTO RIMS.

Do not insulate

Comments: