

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRCOM20150014, Building Permit - Commercial
Address: 508 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, November 24, 2015

Partial Correction
1 Misc 1

OK TO COVER WHEN READY ACT CEILINGS AT MAIN CORRIDORS
AT: LEVEL 3; LEVEL 2; LEVEL 1; LEVEL 4; E219; **E319;**

E119: NO GRID; NOT READY FOR INSPECTION
E419: FIRE-STOP PENETRATION BY 6" PVC PIPE NEAR E WALL

Rated Assembly Inspection	John Borns	Partial	Tuesday, November 24, 2015
----------------------------------	------------	---------	----------------------------

Partial Correction
2 Misc 1

**ELEVATOR SHAFT LID -- OK TO COVER WHEN READY: 1ST LAYER
5/8" TYPE X GWB;**

Comments: