

Temporary Certificate of Occupancy

Permit #: PRRES20151242
Address: 313 SE MILL CREEK DR, LEES SUMMIT, MO 64063
Inspected On: Monday, November 30, 2015
Inspected By: Mike CopelandMike Copeland
Expiration Date: 12/31/2015 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Monday, November 30, 2015

Corrective Action Required:

1	Misc 1	-INSTALL SOD -DRIVEWAY NOT APPROVED ON RECORD -ALL SIDING IS LESS THAN 2" ABOVE PATIO CONCRETE SLAB AND 6" ABOVE SOIL SHALL BE TREATED WOOD -CANNOT POUR THE CONCRETE STAIR TO THE SIDING. SAME MINIMUM 2" CLEARANCE FROM CONCRETE IS REQUIRED -BRING WATER METER UP TO FINAL GRADE -SEAL FRONT GARAGE LIGHTS
---	--------	--

Underslab Plumbing Inspection - Residential	Mike Copeland	Passed	Monday, November 30, 2015
--	---------------	--------	------------------------------

GROUND ROUGH APPROVED PER DYE TEST ONLY