

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152126, Building Permit - Commercial  
Address: 600 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection</b> <b>- Commercial</b>	John Borns	Passed	Tuesday, December 01, 2015

**Comments: OK TO POUR WHEN READY ELEVATOR PIT WALLS AFTER RE-BAR CURTAINS ARE SPACED PER DRAWING AND FORMWORK IS COMPLETED.**