

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20151240, Building Permit - Residential  
Address: 428 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Service Inspection - Residential</b>	Khanh Nguyen	Failed	Wednesday, December 02, 2015

Corrective Action Required

1	Misc 1	NO TEST PRESSURE
---	--------	------------------

**Comments:**

**YOU MUST MAKE SURE THAT THE GAS TEST WILL PASS NEXT TIME; OTHERWISE, A REINSPECTION FEE WILL BE ASSESSED EACH TIME AN INSPECTOR IS HERE FOR THE GAS TEST.**