



## FIRE DEPARTMENT

### PLANS REVIEW CONDITIONS

Permit No:	PRCOM20152366	Date:	December 04, 2015
Project Title:	SAINT LUKES EAST HOSPITAL	Applicant:	
MORGUE			
Location:		JAYHAWK FIRE SPRINKLER CO INC	
	100 NE SAINT LUKES BLVD, LEES	PO BOX 8458	
	SUMMIT, MO 64086	TOPEKA, KS 66608	
Type of Work:			
Occupancy Group:	I-2	Primary:	(913) 422-3770
Description:	MORGUE RENOVATIONS		
Construction Type:	Type IA		
Map Page:	175X		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

#### **Sprinkler Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

SPRINKLER SYSTEM SHALL BE CURRENT WITH THE ANNUAL MAINT/SERVICE. VERIFIED AT INSPECTION.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**