

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20151156  
**Address:** 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086  
**Inspected On:** Monday, December 07, 2015  
**Inspected By:** John BornsMichael WeissenbachJohn Borns  
**Expiration Date:** 12/17/2015 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Temporary C of O	Monday, December 07, 2015

**Corrective Action Required:**

1	Misc 1	FIVE EMERGENCY CIRCUIT ELECTRICAL RECEPTACLES (WITHIN 6' OF EDGE OF SINKS) FOR WATER COOLERS AND REFRIGERATORS AT 5A078, 081 AND 083 NOT GFCI-PROTECTED. EXCEPTION ALLOWABLE IN THIS CASE ONLY IS TO REPLACE DUPLEXES WITH SINGLE RECEPTACLES.
---	--------	--

<b>Alarm Test</b>	Michael Weissenbach	Passed	Monday, December 07, 2015
-------------------	------------------------	--------	------------------------------

<b>Miscellaneous Inspection</b>	John Borns	Passed	Monday, December 07, 2015
---------------------------------	------------	--------	------------------------------

