

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20151723  
**Address:** 3680 NE AKIN DR, Unit:142, LEES SUMMIT, MO 64064  
**Inspected On:** Tuesday, December 08, 2015  
**Inspected By:** Khanh Nguyen Michael Weissenbach  
**Expiration Date:** 1/8/2016 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Temporary C of O	Tuesday, December 08, 2015

Corrective Action Required:

1	Misc 1	-SECURE FLEXIBLE RACEWAY WITHIN 12" OF THE OVEN DISCONNECT -PROTECT WATER SUPPLY TO BEVERAGE DISPENSER AND ICE MAKER
---	--------	---

<b>Gas Piping Inspection - Commercial</b>	Khanh Nguyen	Passed	Tuesday, December 08, 2015
---	--------------	--------	-------------------------------

<b>Alarm Test</b>	Michael Weissenbach	Passed	Tuesday, December 08, 2015
-------------------	------------------------	--------	-------------------------------

<b>Occupancy Inspection -</b>	Michael	Passed	Tuesday, December
-------------------------------	---------	--------	-------------------

**Fire**

Weissenbach

08, 2015