

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152487, Building Permit - Commercial  
Address: 208 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Wednesday, December 09, 2015
<b>Final Plumbing Inspection - Commercial</b>	John Borns	Passed	Wednesday, December 09, 2015

**Comments: ONE SUPPORT BLOCK AT ROOFTOP GAS PIPING NEEDS TO BE INCREASED IN HEIGHT TO MAKE CONTACT WITH ROOF. CLOSE PERMIT.**