

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151716, Building Permit - Commercial  
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Commercial</b>	John Borns	Partial	Thursday, December 10, 2015

Partial Correction  
1          Misc 1

OK FOR USE & OCCUPANCY AT FOLLOWING SPACES: 115-118  
AFTER FIRE DEPARTMENT ISSUES ARE RESOLVED AND...  
- ALL ELECTRICAL RECEPTACLES ARE SOLID TO BOXES  
- GFCI PROTECTION IS VERIFIED ON RECEPTACLES WITHIN 6' OF  
EDGE OF SINK

**Comments:**