

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20152639, Building Permit - Commercial  
Address: 5050 NE LAKEWOOD WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Friday, December 11, 2015

Corrective Action Required

1	Misc 1	-INSTALL INDEPENDENT SUPPORT WIRES FOR THE MC CABLE AND COLOR TAG OR PAINT THE SUPPORT WIRES -SUPPORT ALL LIGHT FIXTURES AT TWO CORNERS -SUPPORT ALL LOW VOLTAGE WIRING IN A NEAT AND WORKMAN-LIKE MANNER -REMOVE ABANDONED ELECTRICAL
---	--------	---

<b>In-wall Inspection</b>	Khanh Nguyen	Passed	Friday, December 11, 2015
---------------------------	--------------	--------	---------------------------

Comments: