

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20150816, Building Permit - Residential
Address: 513 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Partial	Friday, December 11, 2015

Corrective Action Required

1 Misc 1

THE FOLLOWING COMPONENTS ARE BONDED:
-RETAINING WALLS RABAR; TWO LIGHT NICHES,
POOL SHELL REBAR

Comments: