

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #: PRRES20151618, Building Permit - Residential
Address: 324 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Not Ready	Tuesday, December 15, 2015

Corrective Action Required

1 Misc 1

*****NOT A COMPLETE INSPECTION*****

INSTALL SIDEWALK OR ESCROW

PROVIDE GARAGE SEPARATION

INSTALL SPRINKLER HEAD IN MECH ROOM OR INSTALL 1/2 INCH
GYP

COMPLETE DECK

Comments: