

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRRES20152714, Building Permit - Residential  
Address: 249 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Mike Copeland	Failed	Tuesday, December 15, 2015

Corrective Action Required  
1 Misc 1

PLANS DO NOT SHOW SUBSTITUTE FOR STEEL

**Comments:**