

PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #: PRCOM20151723, Building Permit - Commercial  
Address: 3680 NE AKIN DR, Unit:142, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, December 16, 2015

Corrective Action Required

1	Misc 1	-SECURE FLEXIBLE RACEWAY WITHIN 12" OF THE OVEN DISCONNECT -PROTECT WATER SUPPLY TO BEVERAGE DISPENSER AND ICE MAKER
---	--------	---

Comments: