

# Temporary Certificate of Occupancy

---

**Permit #:** PRRES20151618  
**Address:** 324 SE MILL CREEK DR, LEES SUMMIT, MO 64063  
**Inspected On:** Friday, December 18, 2015  
**Inspected By:** Mike Copeland  
**Expiration Date:** 12/31/1899 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Temporary C of O	Friday, December 18, 2015

Corrective Action Required:

1	Misc 1	-SOUTH MASTER BATH WINDOW IS REQUIRED TO BE TEMPERED SAFETY GLASS -INSTALL SOD SPLASHBLOCKS
---	--------	--