

Temporary Certificate of Occupancy

Permit #: PRRES20151618
Address: 324 SE MILL CREEK DR, LEES SUMMIT, MO 64063
Inspected On: Friday, December 18, 2015
Inspected By: Mike CopelandMike Copeland
Expiration Date: 1/29/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Friday, December 18, 2015

Corrective Action Required:

1	Misc 1	-SOUTH MASTER BATH WINDOW IS REQUIRED TO BE TEMPERED SAFETY GLASS -INSTALL SOD SPLASHBLOCKS
---	--------	--

Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Friday, December 18, 2015
---	---------------	------------------	------------------------------

Corrective Action Required:

1	Misc 1	-SOUTH MASTER BATH WINDOW IS REQUIRED TO BE TEMPERED SAFETY GLASS -INSTALL SOD SPLASHBLOCKS
---	--------	--